

Fire Research Note No. 810

THE HBRARY
FIRE RICHARD STATION
BOWN OF WOOD
1 183.
110 A99FR - N 810

PRE-133UED AS CP 32/75

THE BEHAVIOUR OF AUTOMATIC FIRE DETECTION SYSTEMS

by

J. F. FRY and CHRISTINE EVELEIGH March 1970

FIRE RESEARCH STATION

F.R. Note No.810 March 1970.

THE BEHAVIOUR OF AUTOMATIC FIRE DETECTION SYSTEMS

bу

J. F. Fry and Christine Eveleigh

SUMMARY

An examination has been made of the frequency and reasons for the occurrence of false calls made by automatic fire detection systems. These appear to be about 11 times as frequent as calls to genuine fires. About one quarter of false calls are attributed to ambient conditions, one half to mechanical and electrical problems and about 17 per cent to failure in or misuse of the communications systems. Where automatic systems are installed about 68 per cent of calls to genuine fires are made by them.

KEY WORDS: Detector fire, Alarm, Alarm false, Automatic

Crown copyright

This report has not been published and should be considered as confidential advance information. No reference should be made to it in any publication without the written consent of the Director of Fire Research.

MINISTRY OF TECHNOLOGY AND FIRE OFFICES' COMMITTEE
JOINT FIRE RESEARCH ORGANIZATION

THE BEHAVIOUR OF AUTOMATIC FIRE DETECTION SYSTEMS

bу

J. F. Fry and Christine Eveleigh

INTRODUCTION

It has been suspected for some time that the frequency of false alarms originating from automatic fire detection equipment is large in comparison with that of calls to genuine fires, and such information as could be obtained from fire protection experts in other countries has tended to indicate that this is a universal experience. There has, however, been little quantitative information available on either the frequencies of false alarms or their causes. At the request of the Home Office, the Fire Research Station undertook a study to provide further information, based on reports received from fire brigades on all fire incidents in premises fitted with automatic detection equipment and on all false alarms given by them. The study covered a period of one year (1968) and involved the brigades in completing the special report form reproduced in Appendix 1. It was intended to provide information on the operation of all automatic detection systems in buildings, whether linked directly to the brigade or not.

THE INFORMATION RECEIVED

The investigation was primarily concerned with occurrence of false alarms to fire brigades, and for this purpose a false alarm was defined as any fire call to premises equipped with an automatic alarm system at which there was, in fact, no fire. Thus it included all false calls received and was not confined to those incidents in which a mechanical or electrical fault occurred in the equipment. It did not, however, include fault signals correctly given by the equipment (i.e. automatic indications that a fault had developed).

The main groups of detector systems in use are those actuated by heat and those actuated by smoke. In addition it appears from the fire brigade returns that there are appreciable numbers of 'smoke and heat' systems, and of buildings in which a mixture of systems exist together. Brigades also submitted returns for buildings in which sprinkler systems actuated alarms at the brigades and for some with manually operated alarms.

Among the items requested in the form were the name of the maker of the equipment involved and the trade name of the system. It was intended that makers should be given information on the incidents involving their own equipment. In the event this proved to be extremely difficult because of confusion between the two questions, and because of the large number of systems which appeared to incorporate equipment of several different makes. Where possible, however, lists of incidents (necessarily incomplete) were sent to the makers concerned.

No information was obtained on the age and condition of the installations.

RESULTS OF ANALYSIS

CALLS RECEIVED

The calls received through the operation of various types of equipment are summarised in Table (i) from which it will be seen that, taking all types of equipment together, false calls outnumbered actual fire calls in the ratio of about 11:1. There were differences between the ratios for different types of equipment which ranged from about $4\frac{1}{2}$:1 to about 23:1. It is of interest to note that sprinklers produced more than 10 false calls for each genuine fire and that even with manual alarm systems the ratio was about $4\frac{1}{2}$:1.

Table (i) Summary of calls received

	No.of calls to fire		No. of	Ratio of	
Type of system	By system installed	By other means	false calls	false calls : fire calls	
All types	489	288	5440	11.1	
Heat Smoke Sprinkler Manual Mixed Heat and smoke Unspecified	193 101 101 55 18 18	105 37 125 10 6 2	2146 1429 1048 243 137 410 27	11.1 14.1 10.4 4.4 7.6 22.8 9.0	

Note: There was also one false call from gas detector equipment

The numbers of false calls and fire calls received from different types of equipment are given for each type of occupancy (by Standard Industrial Classification Orders) in Tables 1(a)-1(g) in Appendix 2.

REASONS FOR FALSE CALLS

The reported reasons for false calls are given for each type of equipment in Table 2 of Appendix 2. Table (ii) is an overall summary for all types of equipment.

Table (ii) Summary table of reasons for false calls

Reason for false call		all types of ipment
	No.	Per cent
Total (all reasons)	5441	100
Ambient conditions (Total) Extraneous heat and smoke High ambient temperature Condensation, snow, rain, etc. Low ambient temperature Steam, vapour Draught, high wind	1410 951 233 153 37 29	25.9 17.5 4.3 2.8 0.7 0.5 0.1
Mechanical and electrical (Total) Defective wiring on control unit Defective head Surge in mains Miscellaneous (e.g. broken pipe) Direct impact on head Vibration of system Shock (e.g. falling weight) Voltage drop, power cut Defective push button, etc.	2507 602 539 411 293 244 215 151 42	46.1 11.1 9.9 7.6 5.4 4.5 4.0 2.8 0.8 0.2
Communication (Total) Testing, maintenance not notified G.P.O. activity Defect in connection to brigade	901 478 335 88	16.6 8.8 6.2 1.6
Unspecified and unknown	<u>623</u>	11.5

The reasons shown in the tables have been grouped together to indicate the relative importance of the ambient conditions in which the equipment will have to work, mechanical and electrical faults due to either defects in the equipment or accidental damage, and failure in the communication system. There may be some ambiguity of classification within the three groups (e.g. 'steam, vapour' could possibly have been regarded as 'extraneous heat and smoke' or possibly as 'high ambient temperature'), but the distinction between the main groups themselves is clear.

The occurrence of extraneous heat and smoke is the most important item among the ambient conditions and this could arise from carelessness within the premises, from bad siting of equipment or from unforeseen circumstances.

Under the heading of mechanical and electrical causes the most important are defective wiring and defective heads. These would appear to be equipment faults but other items listed in this group could be due to carelessness within the premises or to external conditions which the equipment is not designed to withstand.

The main communication fault appears to be testing or maintenance without previous notification to the fire brigade.

CONNECTIONS TO BRIGADES

The types of connections to brigades for equipment from which false calls were received are shown in Table 3 of Appendix 2. The most frequent type in each of the systems was the individual direct line. As may be seen from the summary in Table (iii), these and the 999 automatic dialler together made up about 80 per cent of the connections.

Table (iii) Types of connection to brigades for equipment from which false calls received

Type of connection	No. of false calls
Total (all types)	5441
Individual direct line 999 Automatic dialler Commercial central alarm station Exchange telephone (manual) V.F. Remote control, System A Shared direct line (e.g. alarm company's multi-channel Fire telephone Mixed Other and unspecified	3976 374 320 289 137 111 52 17

FAILURES AND DELAYS

In addition to information on false calls and successful calls to fires, brigades recorded those occasions on which they had been called to fires of which they had not received notification through the operation of the alarm system installed in the premises. Detailed figures are given in Table 4 of Appendix 2. In some incidents the alarm systems did not operate at all and these have been regarded as 'failures', although they include a high proportion in which the fire was dealt with quickly, before the automatic system had time to operate. In other cases the alarm system operated, but only after the brigade had been notified by other means; these have been classified as 'delays'. An overall summary of the reasons is given in Table (iv).

Table (iv) Reason for failure or delay - call received by other means

Suspected reason for failure or delay	Failure	Delays.
Total (all reasons)	154	134
Insufficient heat or smoke Disconnection or maintenance Manual system operated before automatic Failure of connection to brigade Ventilation or currents at ceiling level Failure of detector head(s) Failure of control equipment Unknown or unspecified	111 20 - 7 6 5 5	19 2

TIMES OF CALLS

ζ.

Since automatic detectors are likely to be of most value when there are few human observers about, it is of interest to see how the frequencies of fire calls and false callse are distributed throughout the day. Detailed information on this is given for the various types of system in Tables 5(a)-5(g) in Appendix 2. Table (v) summarises these figures for all types of equipment and shows the frequencies as 3 hourly totals. The frequencies of false calls are also shown with the total incidents in Fig.1. Although the two graphs are of similar shape they are not completely parallel and indicate that the ratio of false to total calls is slightly higher during the day than during the night.

Table (v) Times of fire calls and false calls

Time of call	Total incidents	False calls	Fire calls Automatic system	other
Midnight - 02.59 03.00 - 05.59 06.00 - 08.59 09.00 - 11.59 12.00 - 14.59 15.00 - 17.59 18.00 - 20.59 21.00 - 23.59 Unspecified	435 405 705 1333 1187 1060 647 408 37	370 359 634 1199 1042 921 536 351 28	38 24 41 87 100 92 74 32	27 22 30 47 45 47 37 25 8

The time distributions of calls to fires by the automatic systems and by other means are shown graphically in Fig.2. Again the graphs are of the same general form, but the relative effectiveness of the automatic systems appears to be greater during the day time than at night.

DISCUSSION

It is clear that the ratio of false calls to actual fire calls given by automatic systems of all types is high; on average about 11:1. Nevertheless this is not, in itself, an indication of gross overall imefficiency. reducing the sensitivity of detecting devices it would be possible to eliminate a large number of false calls, but if this were carried too far the number of failures to detect real fires would increase to an unacceptable level. Ideally the sensitivity level would be selected, on economic grounds, so that the (optimal) level would minimise the sum of the costs and losses. The costs would include the costs of installation and maintenance of the equipment and the cost of dealing with both genuine and false calls, while the losses would include both the direct and the consequential losses by fire. Not only is this beyond the scope of the present note, but a considerable amount of economic information (not at present available) would be necessary to make this ideal assessment. Meanwhile it is relevant to note that selection of the sensitivity level is mainly related to the ambient conditions in which the equipment has to operate, and that these conditions were believed to be responsible for only about one quarter of the false calls received during the investigation.

Among the mechanical and electrical faults, which together appear to account for almost half of the false calls, some (such as defective wiring on control units and defective heads) should be susceptible to reduction by improved inspection and maintenance; others (impact, shock, etc.) require attention to works discipline.

An appreciable reduction in communication faults would appear to be possible given adequate attention to testing and maintenance procedure, in particular notification of brigades that these activities are taking place.

It appears that the majority of failures to detect fires result from the evolution of insufficient heat or smoke and this would be expected if many fires are detected in their very early stages by factory personnel. It is surprising, therefore, to find that proportionately more fires fall into this category at night time than during the day.

CONCLUSIONS

The ratio of false calls to genuine fire calls given by automatic systems of all types is about 11:1.

About one quarter of the false calls received are attributed to ambient conditions, almost one half to mechanical and electrical problems and approximately 17 per cent arise from the communication system.

The majority of connections to brigades are by individual direct line and 999 automatic diallers.

About 68 per cent of calls to genuine fires are made by automatic systems, where these are installed, and the remainder by other means. The automatic system does not operate on about 53 per cent of occasions on which calls are received by other means, but in about 73 per cent of these 'failure to operate' there is insufficient heat or smoke produced by the fire; in many instances this is likely

to be because the fire is dealt with promptly when discovered by human observers. The reasons for delays in the operation of the automatic system which result in a call being received by other means are generally not known.

ACKNOWLEDGMENT

Thanks are due to the fire brigades in England and Wales and in Scotland who provided the information on which this report is based.

MINISTRY OF TECHNOLOGY AND FIRE OFFICES' COMMITTEE JOINT FIRE RESEARCH ORGANIZATION

Report on Fires or False Alarms in Buildings Equipped with Automatic Fire Detection Systems

This report is intended to provide information on the operation of automatic fire detection systems in buildings whether the detection system is linked to the brigade directly or not. Please complete and tick appropriate boxes for all fires in such premises, whether the system signals an alarm or not, and for all false alarms, i.e. warnings of fire where no fire exists. Do not use for fault signals only. Incidents in buildings in which an automatic sprinkler system activates an alarm at the brigade should be included. NOTE Part IV should be wholly or partly completed only where actually relevant. PART I - Details of incident 1. Nature of incident (a) Fire - call received by automatic alarm K433 No. (b) Fire - call received by other means K433 No. (c) False alarm 2. Name of occupier and address Risk Category of Area 4. Date of incident 5. Time of call PART II - Details of system 6. Name of maker (e.g. A.F.A., Gent etc) Trade name of system NOTE Specify names of system and detector if necessary to define completely. Type of system Temperature setting or B.S.3116 classification, if known (a) Heat (b) Smoke (c) Alarm operated by sprinkler system (Specify) (d) Other 9. Type of wiring (a) Metal sheathed cable (b) Cable in conduit (Specify) (c) Other 10.

(e) Commercial central alarm station

Type	of connection to brigade			
(a)	999 Automatic dialler		Fire telephone	
(b)	Individual direct line	(g)	Exchange telephone (manual)	
(c)	Shared direct line (e.g. alarm company's multi-channel)	(h)	Other (specify)	
(a)	V.F. Remote Control, System A		•••••	•••

	PART III - Details of building compartment in which alarm arises.
11.	(a) Approx. height ft (b) Widthft
	(c) Length ft
12.	Shape of ceiling
	(a) Flat
	(b) Flat with joists showing (approx. spacing ft)
	(c) Northlight
	(d) Ridge (e) Clerestory
-	(f) Other (specify)
	PART IV - Details of failure or delay in giving alarm.
17	
13.	Suspected reason for failure (or delay) of system Delay Failure
	(a) Failure of detector head/heads
	(b) Failure of wiring to head/heads
• •	(c) Ventilation currents at ceiling level
	(d) Obstructions at ceiling level
	(e) Failure of control equipment
	(f) Failure of connection to brigade
	If (f), specify briefly if possible
	(g) Disconnection, e.g. for maintenance
	If (g), specify briefly if possible
	•••••••••••••••••••••••••••••••
14.	Suspected reason for false alarm
^	(a) Extraneous heat Specify
	(b) Extraneous smoke Specify
	(c) High ambient temperature
-	(d) Low ambient temperature (e) Vibration of system
	(f) Shock on system, e.g. weight falling on floor above
	(g) Direct impact on head Specify
	(h) Testing/maintenance without warning brigade
	(i) Defective head
	(j) Defective wiring or control unit Specify
	(k) Defective connection to brigade Specify
	(1) G.P.O. activity
15.	Interference with system
	(a) Accidental (b) Suspected malicious
	(c) Unknown
16.	Other remarks (Please add any other information you consider relevant)
	formation (Troduct and only comer time and how compared to to diff.)

Table 1(a) Heat detectors - fire calls and false calls by occupancy

APPENDIX 2

S.I.C.	Classification	Total incidents	False calls	Fire call Automatic system	. 1
All	Totals	2444	2146	193	105
XI XI XX XIII AIII AII AI	Agriculture, forestry, fishing Food, drink, tobacco Chemicals, allied industries Metal manufacture Engineering, electrical goods Shipbuilding, marine engineering Vehicles Metal goods not elsewhere specified Textiles Leather, leather goods, fur Clothing, footwear Bricks, pottery, glass, cement, etc. Timber, furniture, etc. Paper, printing, publishing Other manufacturing industries Construction Gas, electricity, water Transport, communication Distributive trades Insurance, banking, finance Professional, scientific services Miscellaneous services Public administration, defence	1 123 147 73 226 20 104 51 149 35 52 44 196 64 18 30 124 376 42 233 180 125	1 117 62 204 16 96 45 123 20 50 38 166 54 17 29 112 341 39 206 144 116	8 18 2 6 3 19 1 5 1 20 9 1 1 9 21 17 19	- 4 16 3 4 2 2 3 7 1 4 0 1 - 3 4 2 0 17 2
	Dwellings, unknown, unclassified	38	37	1	-

Table 1(b) Smoke detectors - fire calls and false calls by occupancy

S.I.C.	Classification	Total incidents	False calls	Fire call Automatic system	- 1
All	Totals	1567	1429	101	37
VIX VX VX VIX VIX VIX VIX VIX VIX VIX VI	Agriculture, forestry, fishing Mining, quarrying Food, drink, tobacco Chemicals, allied industries Metal manufacture Engineering, electrical goods Shipbuilding, marine engineering Vehicles Metal goods not elsewhere specified Textiles Clothing, footwear Bricks, pottery, glass, cement, etc. Timber, furniture, etc. Paper, printing, publishing Other manufacturing industries Construction Gas, electricity, water Transport, communications Distributive trades Insurance, banking, finance Professional, scientific services Miscellaneous services Public administration, defence Dwellings, unknown, unclassified	3 2 107 52 27 112 16 69 30 52 33 7 10 68 35 11 43 123 288 95 142 62 156 24	3 2 103 51 24 93 16 55 25 44 32 7 9 730 9 42 82 132 84 146 21	1 3 14 11 5 5 1 1 1 10 6 4	25-3-33251445-

Table 1(c) Sprinklers - fire calls and false calls by occupancy

S.I.C.	Classification	Total incidents	False calls	Automatic	
All	Totals	1274	1048	101	125
VIII VI VI VI	Agriculture, forestry, fishing Food, drink, tobacco Chemicals, allied industries Metal manufacture Engineering, electrical goods Shipbuilding, marine engineering Vehicles Metal goods not elsewhere specified Textiles Leather, leather goods, furs Clothing, footwear Bricks, pottery, glass, cement, etc. Timber, furniture, etc. Paper, printing, publishing Other manufacturing industries Gas, electricity, water Transport, communication Distributive trades Insurance, banking, finance Professional, scientific services Miscellaneous services Public administration, defence Dwellings, unknown, unclassified	2 63 86 16 52 3 47 13 187 9 31 26 69 162 76 5 61 261 8 19 28 35 15	2 53 65 14 44 3 32 134 9 29 24 53 60 50 231 7 9 25 17	12 - 4 - 2 - 22 - 1 - 6 16 9 - 8 15	- 4 9 2 4 - 12 1 1 1 2 1 1 7 - 1 2 2 1 - 3 3 1

Table 1(d) Manual alarms - fire calls and false calls by occupancy

S.I.C. Order	Classification	Total incidents	False calls	Fire cal Installed system	
All	Totals	308	243	55	10
VIII VIII VIII VIII VIII VIII VIII VII	Food, drink, tobacco Chemicals, allied industries Metal manufacture Engineering, electrical goods Shipbuilding, marine engineering Vehicles Metal goods not elsewhere specified Textiles Clothing, footwear Bricks, pottery, glass, cement, etc. Timber, furniture, etc. Paper, printing, publishing Other manufacturing industries Gas, electricity, water Transport, communication Distributive trades Insurance, banking, finance Professional, scientific services Miscellaneous services Public administration, defence Unknown, unclassified	18 9 2 10 2 13 3 56 1 2 2 14 26 15 19 35 4 48 14 9 6	16 7 1 7 2 9 3 2 1 1 17 13 18 3 3 4 4 3 14 8 6	2 1 1 3 - 3 - 2 9 - - 3 9 1 - 1 - 2 -	-1 1 - 1 - 1 - 1 - 3 - 4 -

Table 1(e) Detectors of mixed types - fire calls and false calls by occupancy

S.I.C. Order	Classification	Total incidents	False calls	Fire cal Automatic system	, , ,
All	Totals	161	137	18	6
XXIX XXIII XXIX XXIX XXIX XIV XIV XIV XI	Food, drink, tobacco Chemicals, allied industries Engineering, electrical goods Vehicles Metal goods not elsewhere specified Textiles Leather, leather goods, fur Timber, furniture, etc. Paper, printing, publishing Other manufacturing industries Gas, electricity, water Transport, communication Distributive trades Insurance, banking, finance Professional, scientific services Miscellaneous services Public administration, defence Dwellings, unknown, unclassified	7 10 8 2 1 12 2 12 9 12 2 16 24 3 22 5 4	6 7 8 1 1 8 2 6 9 10 1 14 21 3 2 5 3 10	- 2 - 1 - 3 - 6 - 1 1 1 3 	1 1 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -

Table 1(f) Heat and smoke detectors - fire calls and false calls by occupancy

s.i.c	Classification	Total incidents	False calls	Fire cal Automatic system	
All	Totals	430	410	18	2
VY IIV IIV IIV IIV IIV IIV IIV	Food, drink, tobacco Chemicals, allied industries Metal manufacture Engineering, electrical goods Shipbuilding, marine eingeering Vehicles Metal goods not elsewhere specified Textiles Leather, leather goods, fur Clothing, footwear Timber, furniture, etc. Paper, printing, publishing Other manufacturing industries Construction Gas, electricity, water Transport, communication Distributive trades Insurance, banking, finance Professional, scientific services Miscellaneous services Public administration, defence Dwellings, unknown, unclassified	10 7 17 31 3 1 7 10 1 6 2 10 12 8 29 16 135 30 28 32 5	10 7 17 31 3 1 6 10 1 6 2 9 10 7 14 130 27 14 130 27 31 5	- - 1 - - 2 1 2 1 5 4 - 1	

Table 1(g) Detectors of unrecorded type - fire calls and false calls by occupancy

S.I.C. Order	Classification	Total incidents	False calls		Other
A11	Totals	33	.27	3	3
AXIXX IIXX IXX IXX IXX IXX IXX IXX IXX I	Agriculture, forestry, fishing Chemicals, allied industries Engineering, electrical goods Textiles Paper, printing, publishing Other manufacturing industries Transport, communication Distributive trades Insurance, banking, finance Professional, scientific services Miscellaneous services Public administration, defence Dwellings, unknown, unspecified	1 2 4 3 2 2 2 7 1 2 1 4 2	1 1 1 2 2 2 6 1 2 1 4 2	- 1 2 - - - - - - -	1 1 - 1

Table 2 Reasons for false calls

Perented manager for folice soll	To (all t	otal Sypes)			Туре	of sys	tem			
Reported reason for false call	No.	Per cent	Heat.	Smoke	Sprinkler	Manual	Mixed	Heat and smoke	Gas	Unspecified
Totals	54.41	100	2146	1429	1048 .	243	1 37	410	1	. 27
Ambient conditions (Totals) Extraneous heat and smoke High ambient temperature Condensation, snow, rain, etc. Low ambient temperature Steam, vapour Draught, high wind	1410 951 233 153 37 29	25.9 17.5 4.3 2.8 0.7 0.5 0.1	561 306 180 44 16 13		55 24 15 9 5 2	<u>8</u> 3131	12 5 2 3 2	137 87 25 15 6 3	0 1 1 1 1 1	6 3 - 1 1 -
Mechanical and electrical (Totals) Defective wiring on control unit Defective head Surge in mains Miscellaneous (e.g. broken pipe) Direct impact on head Vibration of system Shock (e.g. by falling weight) Voltage drop, power cut Defective push button, etc.	2507 602 539 411 293 244 215 151 42 10	46.1 11.1 9.9 7.6 5.4 4.5 4.0 2.8 0.8 0.2	931 258 170 12 93 168 109 102 17 2	21 9	695 97 13 392 91 32 38 24 6	140 26 2 2 64 22 15 7	38 17 4 3 2 6 2 2 2	179 49 67 2 16 25 4 8 2	1 - 1	10 2 1 - 5 1 - 1
Communication (Totals) Testing, maintenance not notified G.P.O. activity Defect in connection to brigade	901 478 335 88	16.6 8.8 6.2 1.6	<u>394</u> 170 186 <i>3</i> 8	158 70 70 18	227 175 35 17	38 26 10 2	33 16 15 2	<u>45</u> 18 19 8	<u>o</u> - -	<u>6</u> 3 13
Unspecified and unknown	623	11.5	260	127	71	57	54	49	<u></u>	5

Table 3 Type of connection to brigade for equipment from which false calls were received

	Total ((all types)	Type of system							
Type of connection to F.B.	No.	Per cent	Heat	Smoke	Sprinkler	Manual	Mixed	Heat and smoke	Gas	Unspecified
Totals	5441	100	2146	1429	1048	243	137	410	1	27
Individual direct line	3976	73.2	1614	992	811 ⁻¹	152	87	309	1	10
999 Automatic dialler	374	6.9	146	112	78	9	10	18	_	1
Commercial central alarm station	320	5.9	126	70		22	24	11	_	2 ·
Exchange telephone (manual)	289	5.3	94	109	38	22	2	23	_	1
V.F. Remote control, System A	137	2.5	36	50	7	4	4	36	-	<u>-</u>
Shared direct line (e.g. alarm company's multi channel)	111	2.0	62	18	15	10	4	2	-	-
Fire telephone	52	0.1	18	27	2	3	-	1	-	1
Mixed	17	0.03	8	2	1	4	1	1	-	_
Other and unspecified	165	3.0	42	49	31	17	5	9	_	12

Table 4 Suspected reason for failure or delay in alarm equipment where call to fire was received by other means

								Тур	e of	sys:	tem				
Suspected reason for failure or delay	Total failures and delays	Не	æt	Smo	ke	Sprin	kler	Man	ual	Mix	ed	Heat smo		Unspec	ified
	all types		D	F	D	F	Ď	F	D	F	D	F	D	F	D
Totals	288	61	44.	12	25	74	51	1	9	3	3	2	_	1	2
Insufficient heat or smoke Disconnection or maintenance Manual system operated before automatic Failure of connection to brigade Ventilation or currents at ceiling level Failure of detector head/heads Failure of control equipment Unknown or unspecified	111 23 19 9 6 5 110	45 10 - 1 3 1 1	2 11	- 2 3 1	- - - - - 25	58 7 - 4 1 1 3	- 1 6 2 - - 42	1	2 7	1 1 - 1	- - - - - 3	1 - 1	-	1	2

.Table 5(a) Heat detectors - times of calls

Time of call	Total incidents	False calls	Fire call Automatic system	ls by: Other means
All times	2444	2146	193	105
Midnight - 00.59 01.00 - 01.59 02.00 - 02.59 03.00 - 03.59 04.00 - 04.59 05.00 - 05.59 06.00 - 06.59 07.00 - 07.59 08.00 - 08.59 09.00 - 09.59 10.00 - 10.59 11.00 - 11.59 12.00 - 12.59 13.00 - 13.59 14.00 - 14.59 15.00 - 15.59 16.00 - 16.59 17.00 - 17.59 18.00 - 18.59 19.00 - 19.59 20.00 - 20.59 21.00 - 21.59 22.00 - 23.59 Unspecified	38 48 60 38 63	37 35 38 48 31 51 69 122 187 170 184 128 155 191 168 117 84 81 57 55 28 25 41 11	8534559555116647372279465-	7-26723436677513724563225

Table 5(b) Smoke detectors - times of calls

Time of call	Total incidents	False calls	Fire call Automatic system	other means
All times	1567	1429	101	37
Midnight - 00.59 01.00 - 01.59 02.00 - 02.59 03.00 - 03.59 04.00 - 04.59 05.00 - 05.59 06.00 - 06.59 07.00 - 07.59 08.00 - 08.59 09.00 - 09.59 11.00 - 11.59 12.00 - 12.59 13.00 - 13.59 14.00 - 14.59 15.00 - 15.59 16.00 - 16.59 17.00 - 17.59 18.00 - 18.59 19.00 - 19.59 20.00 - 20.59 21.00 - 21.59 22.00 - 23.59 Unspecified	28 34 35 26 33 34 32 45 99 110 124 77 63 50 40 32 310	27 31 33 49 106 118 85 116 70 54 38 37 23 31 85 31 85 31 85 31 85 85 85 85 85 85 85 85 86 86 86 86 86 86 86 86 86 86 86 86 86	11-21-24773688897542-231	-223-2-1112-52223-23121

Table 5(c) Sprinklers - times of calls

Time of call	Total incidents	False calls	Fire call Automatic system	ls by: Other means
All times	1274	1048	101	125
Midnight - 00.59 01.00 - 01.59 02.00 - 02.59 03.00 - 03.59 04.00 - 04.59 05.00 - 06.59 07.00 - 07.59 08.00 - 08.59 09.00 - 09.59 10.00 - 10.59 11.00 - 11.59 12.00 - 12.59 13.00 - 13.59 14.00 - 14.59 15.00 - 15.59 16.00 - 16.59 17.00 - 17.59 18.00 - 19.59 20.00 - 20.59 21.00 - 21.59 22.00 - 23.59 Unspecified	57 49 49 51 35 46 57 71 88 76 67 77 48 43 39 67 77 48 43 43 43 43 43 43 43 43 43 44 43 43 44 43 44 43 44 44	499184109495990252444235 431435445990252444235	257211232264063245863232-	6511 - 35206689289185734141

Table 5(d) Manual alarms - times of calls -

	, 			
Time of call	Total incidents	False calls	Fire call Installed system	ls by: Other means
All times	308	243	55	10
Midnight - 00.59 01.00 - 01.59 02.00 - 02.59 03.00 - 03.59 04.00 - 04.59 05.00 - 05.59 06.00 - 06.59 07.00 - 07.59 08.00 - 08.59 09.00 - 09.59 10.00 - 10.59 11.00 - 11.59 12.00 - 12.59 13.00 - 13.59 14.00 - 14.59 15.00 - 16.59 17.00 - 17.59 18.00 - 18.59 19.00 - 19.59 20.00 - 20.59 21.00 - 21.59 22.00 - 23.59 Unspecified	5 1 5 5 5 2 7 4 7 0 9 27 22 11 10 6 0 2 11 10 6 2	3 -44426037638859506275862	2111111432333443613332111	

Table 5(e) Detectors of mixed types - times of calls

Time of call	Total incidents	False calls	Fire cal Automatic system	ls by: Other means
All times	1 61	137	18	6
Midnight - 00.59 01.00 - 01.59 02.00 - 02.59 03.00 - 03.59 04.00 - 04.59 05.00 - 05.59 06.00 - 06.59 07.00 - 07.59 08.00 - 08.59 09.00 - 09.59 10.00 - 10.59 11.00 - 11.59 12.00 - 12.59 13.00 - 13.59 14.00 - 14.59 15.00 - 15.59 16.00 - 16.59 17.00 - 17.59 18.00 - 18.59 19.00 - 19.59 20.00 - 20.59 21.00 - 21.59 22.00 - 23.59 Unspecified	5642332363754710096637261	3532322362728699085626161	-111-241211-11	2

Table 5(f) Heat and smoke detectors - times of calls

<u></u>	·			gradient de la company
Time of call	Total incidents	False calls	Fire call Automatic system	s by: Other means
All times	430	410	18	2
Midnight - 00.59 01.00 - 01.59 02.00 - 02.59 03.00 - 03.59 04.00 - 04.59 05.00 - 05.59 06.00 - 06.59 07.00 - 07.59 08.00 - 08.59 09.00 - 09.59 10.00 - 10.59 11.00 - 11.59 12.00 - 12.59 13.00 - 13.59 14.00 - 14.59 15.00 - 15.59 16.00 - 16.59 17.00 - 17.59 18.00 - 18.59 19.00 - 20.59 21.00 - 21.59 22.00 - 22.59 23.00 - 23.59 Unspecified	7 8 10 4 6 9 12 17 13 29 31 34 29 31 13 19 20 7 11 9 2	7 8 10 4 6 9 1 1 1 7 3 1 8 2 7 9 3 4 8 9 7 1 0 9 1 1 1 2 9 7 1 0 9 1		

Table 5(g) Detectors of unrecorded type - times of calls

Time of call	Total incidents	False calls	Fire cal Automatic system	other
All times	33	27	3	3
Midnight - 00.59 01.00 - 01.59 02.00 - 02.59 03.00 - 03.59 04.00 - 04.59 05.00 - 05.59 06.00 - 06.59 07.00 - 07.59 08.00 - 08.59 09.00 - 09.59 10.00 - 10.59 11.00 - 11.59 12.00 - 12.59 13.00 - 13.59 14.00 - 14.59 15.00 - 15.59 16.00 - 16.59 17.00 - 17.59 18.00 - 18.59 19.00 - 20.59 21.00 - 21.59 22.00 - 22.59 23.00 - 23.59 Unspecified	1 - 1 33 - 1 - 1 1 35 - 31 - 21 2221	1 - 1 3 3 - 1 - 1 1 3 3 - 3 1 - 1 1 1 1		




FIG. 1. THREE-HOURLY FREQUENCIES OF INCIDENTS AND FALSE CALLS




FIG. 2. THREE-HOURLY FREQUENCIES OF FIRE CALLS